



Number	21E0602/02	Replaces	--
Date of issue	19-07-2021	Issued first	19-07-2021
Valid till	19-07-2024	Report number	0026-L-21/2

Declaration
regarding the resistance to root penetration of a root protection layer

DECLARATION OF KIWA BDA EXPERT CENTRE

This declaration is based on a single examination by Kiwa BDA Testing B.V. on one product supplied by

Knauf Insulation d.o.o.

This declaration does not pass a judgment on other products supplied by the manufacturer.
The product was tested according to CEN/TS 14416:2014.

PRODUCT NAME

USRM 500 Urbanscape Root Membrane

TEST RESULTS

After the growing period of six weeks no penetration into or through the test specimens have been observed.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this declaration is still valid.

Kiwa BDA Expert Centre

Department of:
BDA Dak- en Geveladvies B.V.
Avelingen West 33
NL – 4202 MS Gorinchem
P.O. Box 389
NL – 4200 AJ Gorinchem
Tel +31(0)183 669690
groep@bda.nl
www.kiwabda.nl

Copyright© 2021 Kiwa BDA

Knauf Insulation d.o.o.

Trata 32
SL-4220 ŠKOFJA LOKA
Tel +386 (0)4 5114 000
oem@knaufinsulation.com
www.oem.knaufinsulation.com

